

# The Water We Drink

## NATCHITOCHEs WATER SYSTEM

Public Water Supply ID:  
LA1069007

We are pleased to present to you the Annual Water Quality Report for the year 2024. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water source(s) are listed below:

Source Name	Source Water Type	Source Water Body Name
SIBLEY LAKE INTAKE	SURFACE WATER	SIBLEY LAKE
WELL #1	GROUND WATER	N/A

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

A Source Water Assessment Plan (SWAP) is now available from our office. This plan is an assessment of a delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area, and a determination of the water supply's susceptibility to contamination by the identified potential sources. According to the Source Water Assessment Plan, our water system had a susceptibility rating of 'HIGH'. If you would like to review the Source Water Assessment Plan, please feel free to contact our office.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply want to learn more about your drinking water, please contact MAYOR RONNIE WILLIAMS at 318-352-2772.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially for pregnant women, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2024. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years. or a single penny in \$10,000,000.

Picocuries per liter (pCiL) – picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) – nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Treatment Technique (TT) – an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum contaminant level (MCL) – the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal (MCLG) – the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level (MRDL) – the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal (MRDLG) – the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Level 1 Assessment - a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

During the period covered by this report we had the below noted violations of drinking water regulations.

Compliance Period	Analyte	Type
No Violations Occurred in the Calendar Year 2024		

Our water system tested a minimum of 30 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to insure control of microbial growth.

Disinfectant	Date	HIGHEST RAA	UNIT	RANGE	MRDL	MRDLG	Typical Source
CHLORAMINE	2024	2.2	ppm	0.05 – 5.8	4	4	Water Additive Used to Control Microbes
CHLORINE DIOXIDE	2024	.006	ppm	0.0 – 0.05	800	800	Water Additive Used to Control Microbes
CHLORITE	2024	0.77	ppm	0.305 – 0.96	1.0	0.8	By-product of Drinking Water Disinfection

Disinfectant/ By-product	Result value	Health Effects Language if exceeded
CHLORINE DIOXIDE MRDL	Highest daily value	Some infants and young children who drink water chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.
CHLORITE MCL	Highest arithmetic average of monthly sample sets (3 samples in distribution system)	Some infants and young children who drink water containing chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.
BROMATE MCL	Highest running annual arithmetic average, computed quarterly, of monthly samples	Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of getting cancer.

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
ANTIMONY, TOTAL	10/12/2024	5.3	0 – 5.3	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
ATRAZINE	8/21/2023	0.046	0 -0.046	ppb	3	4	Runoff from herbicide used on row crops.
FLUORIDE	10/13/2024	0 - 1.5	0.8	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE-NITRITE	2/4/2024	0.1	0- 0.1	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
OXAMYL	8/21/2023	0.63	0 – 0.63	ppb	200	200	Runoff/leaching from insecticide used on apples, potatoes, and tomatoes.

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	2/4/2024	2.65	0 – 2.65	pCi/L	5	0	Erosion of Natural Deposits
GROSS BETA PARTICLE ACTIVITY	2/4/2024	1.66	1.66	pCi/L	50	0	Decay of natural and man-made deposits.
RADIUM-226	2/4/2024	0.91	0 – 0.91	pCi/L	5	0	Erosion of natural deposits
RADIUM-228	2/4/2024	1.74	0 – 1.74	pCi/L	5	0	Erosion of natural deposits

Lead and Copper	Date	90 <sup>TH</sup> Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2020 - 2023	0.1	0.1 – 0.3	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2020 - 2023	0	0	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	109 MORGAN LANE	2023 - 2024	50	27.7 - 81.9	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	4383 HWY 1	2023 - 2024	47	29.8 - 66.4	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	COLLEGE AVE	2023 - 2024	51	26.1 - 90.1	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	WTP 24 EFFLUENT	2023 - 2024	50	22.7 - 84.3	ppb	60	0	By-product of drinking water disinfection
TTHM	109 MORGAN LANE	2023 - 2024	42	22.1 - 62.2	ppb	80	0	By-product of drinking water chlorination
TTHM	4383 HWY 1	2023 - 2024	39	20.5 - 61.6	ppb	80	0	By-product of drinking water chlorination
TTHM	COLLEGE AVE	2023 - 2024	45	24.4 - 63.4	ppb	80	0	By-product of drinking water chlorination
TTHM	WTP 24 EFFLUENT	2023 - 2024	47	22.9 - 62	ppb	80	0	By-product of drinking water chlorination

Source Secondary Contaminants	Collection Date	Highest Value	Range	Unit	SMCL
ALUMINUM	10/13/2024	0.01	0 - 0.01	MG/L	0.2
CHLORIDE	7/29/2024	35	0 - 35	MG/L	250
HARDNESS, TOTAL (AS CaCO3)	4/15/2024	6	5.5 - 6	MG/L	0
IRON	4/15/2024	0.9	0.73 - 0.9	MG/L	0.3
MANGANESE	10/13/2024	0.02	0.02	MG/L	0.05
PH	4/15/2024	6.65	6.02 - 6.65	PH	8.5
POTASSIUM	2/4/2024	2.1	1.9 - 2.1	MG/L	0
SODIUM	2/4/2024	88.9	78.8 - 88.9	MG/L	0
SULFATE	7/29/2024	17	0 - 17	MG/L	250

Treated Secondary Contaminants	Collection Date	Highest Value	Range	Unit	SMCL
ALUMINUM	2/4/2024	0.8	0.02 – 0.8	MG/L	0.2
CHLORIDE	2/4/2024	24	24	MG/L	250
HARDNESS, TOTAL (AS CaCO3)	2/4/2024	29.8	21.1 – 29.8	MG/L	0
IRON	8/18/2024	0.04	0 – 0.04	MG/L	0.3
MANGANESE	10/13/2024	0.06	0.02 – 0.06	MG/L	0.05
PH	2/4/2024	5.84	5.84	PH	8.5
POTASSIUM	2/4/2024	2.3	2 – 2.3	MG/L	0
SODIUM	2/4/2024	32.6	27 – 32.6	MG/L	0
SULFATE	2/4/2024	55	55	MG/L	250
ZINC	2/4/2024	0.5	0 – 0.5	MG/L	5

Unregulated contaminants are those that do not yet have a drinking water standard set by the USEPA. The purpose of monitoring these contaminants is to help the USEPA decide whether the contaminants should have a standard.

Unregulated Contaminants	Collection Date	Average Concentration	Range	Unit	Sample Point
1004 Bromide	3/6/2018	27.7	n/a	ug/L	Sibley Lake Intake
1004 Bromide	6/7/2018	39.5	n/a	ug/L	Sibley Lake Intake
1004 Bromide	9/20/2018	43.5	n/a	ug/L	Sibley Lake Intake
1004 Bromide	12/20/2018	30.2	n/a	ug/L	Sibley Lake Intake
2920 Total Organic	3/6/2018	6730	n/a	ug/L	Sibley Lake Intake
2920 Total Organic	6/7/2018	7650	n/a	ug/L	Sibley Lake Intake
2920 Total Organic	9/20/2018	6460	n/a	ug/L	Sibley Lake Intake
2920 Total Organic	12/20/2018	5580	n/a	ug/L	Sibley Lake Intake
2456 HAA5	3/6/2018	46.84	6.76 - 50.76	ug/L	WTP 24 Effluent
2457 HAA6Br	3/6/2018	6.76	6.76 - 50.76	ug/L	WTP 24 Effluent
2459: HAA9	3/6/2018	50.76	6.76 - 50.76	ug/L	WTP 24 Effluent
2456 HAA5	6/7/2018	17.94	3.56 - 21.16	ug/L	WTP 24 Effluent
2457 HAA6Br	6/7/2018	3.56	3.56 - 21.16	ug/L	WTP 24 Effluent
2459: HAA9	6/7/2018	21.16	3.56 - 21.16	ug/L	WTP 24 Effluent
2456 HAA5	9/20/2018	17.07	5.01 - 21.41	ug/L	WTP 24 Effluent
2457 HAA6Br	9/20/2018	5.01	5.01 - 21.41	ug/L	WTP 24 Effluent
2459: HAA9	9/20/2018	21.41	5.01 - 21.41	ug/L	WTP 24 Effluent
2456 HAA5	3/6/2018	31.72	7.52 - 38.82	ug/L	4383 Hwy 1
2457 HAA6Br	3/6/2018	7.52	7.52 - 38.82	ug/L	4383 Hwy 1
2459: HAA9	3/6/2018	38.82	7.52 - 38.82	ug/L	4383 Hwy 1
2456 HAA5	6/7/2018	21.1	3.62 - 24.42	ug/L	4383 Hwy 1

Unregulated Contaminants	Collection Date	Average Concentration	Range	Unit	Sample Point
2457 HAA6Br	6/7/2018	3.62	3.62 - 24.42	ug/L	4383 Hwy 1
2459: HAA9	6/7/2018	24.42	3.62 - 24.42	ug/L	4383 Hwy 1
2456 HAA5	9/20/2018	23.14	6.56 - 28.86	ug/L	4383 Hwy 1
2457 HAA6Br	9/20/2018	6.56	6.56 - 28.86	ug/L	4383 Hwy 1
2459: HAA9	9/20/2018	28.86	6.56 - 28.86	ug/L	4383 Hwy 1
2456: HAA5	3/6/2018	16.34	3.5 - 19.5	ug/L	College Avenue
2457: HAA6Br	3/6/2018	3.5	3.5 - 19.5	ug/L	College Avenue
2459: HAA9	3/6/2018	19.5	3.5 - 19.5	ug/L	College Avenue
2456: HAA5	6/7/2018	16.34	3.5 - 19.5	ug/L	College Avenue
2457: HAA6Br	6/7/2018	3.5	3.5 - 19.5	ug/L	College Avenue
2459: HAA9	6/7/2018	19.5	3.5 - 19.5	ug/L	College Avenue
2456: HAA5	9/20/2018	17.98	5.24 - 22.54	ug/L	College Avenue
2457: HAA6Br	9/20/2018	5.24	5.24 - 22.54	ug/L	College Avenue
2459: HAA9	9/20/2018	22.54	5.24 - 22.54	ug/L	College Avenue
2456: HAA5	3/6/2018	31.75	4.8 - 36.2	ug/L	109 Morgan Lane
2457: HAA6Br	3/6/2018	4.8	4.8 - 36.2	ug/L	109 Morgan Lane
2459: HAA9	3/6/2018	36.2	4.8 - 36.2	ug/L	109 Morgan Lane
2456: HAA5	6/7/2018	20.8	2.5 - 23.3	ug/L	109 Morgan Lane
2457: HAA6Br	6/7/2018	2.5	2.5 - 23.3	ug/L	109 Morgan Lane
2459: HAA9	6/7/2018	23.3	2.5 - 23.3	ug/L	109 Morgan Lane
2456: HAA5	9/20/2018	22.1	5.58 - 26.98	ug/L	109 Morgan Lane
2457: HAA6Br	9/20/2018	5.58	5.58 - 26.98	ug/L	109 Morgan Lane
2459: HAA9	9/20/2018	26.98	5.58 - 26.98	ug/L	109 Morgan Lane
Manganese	2/7/5019	8.7	8.7-21.8	ug/L	Water Treatment Plant
Manganese	5/20/2019	21.8	8.7-21.8	ug/L	Water Treatment Plant
Manganese	8/22/19	20.8	8.7-21.8	ug/L	Water Treatment Plant
Algal Toxins	7/2/2019	<0.010	n/a	ug/L	Water Treatment Plant
Cylindrospermopsin	7/2/2019	<0.030	n/a	ug/L	Water Treatment Plant
Algal Toxins	8/22/19	<0.010	n/a	ug/L	Water Treatment Plant
Cylindrospermopsin	8/22/19	<0.030	n/a	ug/L	Water Treatment Plant
Total Microcystins	8/22/2019	<.10	n/a	ug/L	Water Treatment Plant
Anatoxin	9/9/2019	<0.010	n/a	ug/L	Water Treatment Plant
Cylindrospermopsin	9/9/2019	<0.030	n/a	ug/L	Water Treatment Plant
alpha-BHC	8/22/2019	0.0032u	n/a	ug/L	Water Treatment Plant
Chlorpyrifos	8/22/2019	0.0096u	n/a	ug/L	Water Treatment Plant
Dimethipin	8/22/2019	0.065u	n/a	ug/L	Water Treatment Plant
Ethoprop	8/22/2019	0.022u	n/a	ug/L	Water Treatment Plant
Merphos-Oxone	8/22/2019	0.016u	n/a	ug/L	Water Treatment Plant

Unregulated Contaminants	Collection Date	Average Concentration	Range	Unit	Sample Point
Oxyfluoren	8/22/2019	0.013u	n/a	ug/L	Water Treatment Plant
Permethrin	8/22/2019	0.096u	n/a	ug/L	Water Treatment Plant
Tebuconazole	8/22/2019	0.065u	n/a	ug/L	Water Treatment Plant
Butylated hydroxyanisole	8/22/2019	.0096u	n/a	ug/L	Water Treatment Plant
Quinoline	8/22/2019	0.0064u	n/a	ug/L	Water Treatment Plant
O- toluidine	8/22/2019	0.0022u	n/a	ug/L	Water Treatment Plant
n- Butanol	8/22/2019	0.67u	n/a	ug/L	Water Treatment Plant
2-Methoxyethanol	8/22/2019	0.13u	n/a	ug/L	Water Treatment Plant
2- Propen-1-ol (Allyl alcohol)	8/22/2019	0.17u	n/a	ug/L	Water Treatment Plant
Anatoxin	9/19/2020	<0.010	n/a	ug/L	Water Treatment Plant
Cylindrospermosin	9/19/2020	<0.030	n/a	ug/L	Water Treatment Plant
Total Microcystines	10/2/2020	<0.10	n/a	ug/L	Water Treatment Plant
alpha-BHC	11/1/2020	0.0031u	n/a	ug/L	Water Treatment Plant
Chlorpyrifos	11/1/2020	0.0095u	n/a	ug/L	Water Treatment Plant
Dimethpin	11/1/2020	0.064u	n/a	ug/L	Water Treatment Plant
Ethoprop	11/1/2020	0.0095u	n/a	ug/L	Water Treatment Plant
Merphos-Oxone	11/1/2020	0.022u	n/a	ug/L	Water Treatment Plant
Oxyfluoren	11/1/2020	0.016u	n/a	ug/L	Water Treatment Plant
Permrthin	11/1/2020	0.012u	n/a	ug/L	Water Treatment Plant
Profenofos	11/1/2020	0.095u	n/a	ug/L	Water Treatment Plant
Tebuconazole	11/1/2020	0.064u	n/a	ug/L	Water Treatment Plant
Butylated hydroxyanisole	11/1/2020	0.0095u	n/a	ug/L	Water Treatment Plant
Quinoline	11/1/2020	0.0064u	n/a	ug/L	Water Treatment Plant
O-touidine	11/1/2020	0.0022u	n/a	ug/L	Water Treatment Plant
N-Butanol	11/1/2020	0.67u	n/a	ug/L	Water Treatment Plant
2-Methoxyethanol	11/1/2020	.13u	n/a	ug/L	Water Treatment Plant
2-Propen-1-ol (allyl alcohol)	11/1/2020	0.17u	n/a	ug/L	Water Treatment Plant
Germanium	11/1/2020	0.10u	n/a	ug/L	Water Treatment Plant
Manganese	11/1/2020	8.5	n/a	ug/L	Water Treatment Plant



Unregulated Contaminants	Collection Date	Average Concentration	Range	Unit	Sample Point
2459: HAA9	9/20/2018	22.54	5.24 - 22.54	ug/L	College Avenue
2456: HAA5	3/6/2018	31.75	4.8 - 36.2	ug/L	109 Morgan Lane
2457: HAA6Br	3/6/2018	4.8	4.8 - 36.2	ug/L	109 Morgan Lane
2459: HAA9	3/6/2018	36.2	4.8 - 36.2	ug/L	109 Morgan Lane
2456: HAA5	6/7/2018	20.8	2.5 - 23.3	ug/L	109 Morgan Lane
2457: HAA6Br	6/7/2018	2.5	2.5 - 23.3	ug/L	109 Morgan Lane
2459: HAA9	6/7/2018	23.3	2.5 - 23.3	ug/L	109 Morgan Lane
2456: HAA5	9/20/2018	22.1	5.58 - 26.98	ug/L	109 Morgan Lane
2457: HAA6Br	9/20/2018	5.58	5.58 - 26.98	ug/L	109 Morgan Lane
2459: HAA9	9/20/2018	26.98	5.58 - 26.98	ug/L	109 Morgan Lane
Manganese	2/7/5019	8.7	8.7-21.8	ug/L	Water Treatment Plant
Manganese	5/20/2019	21.8	8.7-21.8	ug/L	Water Treatment Plant
Manganese	8/22/19	20.8	8.7-21.8	ug/L	Water Treatment Plant
Algal Toxins	7/2/2019	<0.010	n/a	ug/L	Water treatment Plant
Cylindrospermopsin	7/2/2019	<0.030	n/a	ug/L	Water Treatment Plant
Algal Toxins	8/22/19	<0.010	n/a	ug/L	Water Treatment Plant
Cylindrospermopsin	8/22/19	<0.030	n/a	ug/L	Water Treatment Plant
Total Microcystins	8/22/2019	<.10	n/a	ug/L	Water Treatment Plant
Anatoxin	9/9/2019	<0.010	n/a	ug/L	Water Treatment Plant
Cylindrospermopsin	9/9/2019	<0.030	n/a	ug/L	Water treatment Plant
alpha-BHC	8/22/2019	0.0032u	n/a	ug/L	Water Treatment Plant
Chlorpyrifos	8/22/2019	0.0096u	n/a	ug/L	Water Treatment Plant
Dimethipin	8/22/2019	0.065u	n/a	ug/L	Water Treatment Plant
Ethoprop	8/22/2019	0.022u	n/a	ug/L	Water Treatment Plant
Merphos-Oxone	8/22/2019	0.016u	n/a	ug/L	Water treatment Plant
Oxyfluoren	8/22/2019	0.013u	n/a	ug/L	Water Treatment Plant
Permethrin	8/22/2019	0.096u	n/a	ug/L	Water Treatment Plant
Tebuconazole	8/22/2019	0.065u	n/a	ug/L	Water Treatment Plant
Butylated hydroxyanisole	8/22/2019	.0096u	n/a	ug/L	Water Treatment Plant
Quinoline	8/22/2019	0.0064u	n/a	ug/L	Water treatment Plant
O- toluidine	8/22/2019	0.0022u	n/a	ug/L	Water treatment Plant
n- Butanol	8/22/2019	0.67u	n/a	ug/L	Water Treatment Plant
2-Methoxyethanol	8/22/2019	0.13u	n/a	ug/L	Water Treatment Plant
2- Propen-1-ol (Allyl alcohol)	8/22/2019	0.17u	n/a	ug/L	Water Treatment Plant
Anatoxin	9/19/2020	<0.010	n/a	ug/L	Water Treatment Plant
Cylindrospermopsin	9/19/2020	<0.030	n/a	ug/L	Water Treatment Plant

Unregulated Contaminants	Collection Date	Average Concentration	Range	Unit	Sample Point
Total Microcystines	10/2/2020	<0.10	n/a	ug/L	Water Treatment Plant
alpha-BHC	11/1/2020	0.0031u	n/a	ug/L	Water Treatment Plant
Chlorpyrifos	11/1/2020	0.0095u	n/a	ug/L	Water Treatment Plant
Dimethpin	11/1/2020	0.064u	n/a	ug/L	Water Treatment Plant
Ethoprop	11/1/2020	0.0095u	n/a	ug/L	Water Treatment Plant
Merphos-Oxone	11/1/2020	0.022u	n/a	ug/L	Water Treatment Plant
Oxyfluoren	11/1/2020	0.016u	n/a	ug/L	Water Treatment Plant
Permrthin	11/1/2020	0.012u	n/a	ug/L	Water Treatment Plant
Profenofos	11/1/2020	0.095u	n/a	ug/L	Water Treatment Plant
Tebuconazole	11/1/2020	0.064u	n/a	ug/L	Water Treatment Plant
Butylated hydroxyanisole	11/1/2020	0.0095u	n/a	ug/L	Water Treatment Plant
Quinoline	11/1/2020	0.0064u	n/a	ug/L	Water Treatment Plant
O-touidine	11/1/2020	0.0022u	n/a	ug/L	Water Treatment Plant
N-Butanol	11/1/2020	0.67u	n/a	ug/L	Water Treatment Plant
2-Methoxyethanol	11/1/2020	.13u	n/a	ug/L	Water Treatment Plant
2-Propen-1-ol (allyl alcohol)	11/1/2020	0.17u	n/a	ug/L	Water Treatment Plant
Germanium	11/1/2020	0.10u	n/a	ug/L	Water Treatment Plant
Manganese	11/1/2020	8.5	n/a	ug/L	Water Treatment Plant

#### Unresolved Significant Deficiencies

Unresolved significant deficiencies that were identified during a survey done on the water system are shown below.					
Date Identified	Facility	Code	Activity	Due Date	Description
5/13/2021	Surface Water Treatment Plant	200T1 01	IESWTR ADDRESS DEFICIENCIES	8/29/2021	LAC 51:XII.319.D.24 – System shall ensure that no critical water system component is in poor condition or defective.
5/13/2021	Surface Water Treatment Plant	200T1 01	AO RESOLVE DEFECIENCY SANITARY DEFECTS	7/31/2023	LAC 51:XII.319.D.24 – System shall ensure that no critical water system component is in poor condition or defective.
9/19/2023	CLEAR WELL #2	200T1 03	IESWTR ADDRESS DEFICIENCIES	1/3/2024	LAC 51:XII.319.D.25 – All potable water systems shall be designed, constructed and maintained so as to prevent leakage of water due to defective materials, improper jointing, corrosion, settling, impacts, freezing, or other causes. Valves and blow-offs shall be provided so that necessary repairs can be made with a minimum interruption of service.

9/19/2023	CLEAR WELL #2	200T1 03	IESWTR APPROVED CORRECTIVE ACTION PLAN	8/29/2024	LAC 51:XII.319.D.25 – All potable water systems shall be designed, constructed and maintained so as to prevent leakage of water due to defective materials, improper jointing, corrosion, settling, impacts, freezing, or other causes. Valves and blow-offs shall be provided so that necessary repairs can be made with a minimum interruption of service.
9/19/2023	GST #3, GROUND STORAGE TANK AT PLANT	200T1 01	IESWTR ADDRESS DEFICIENCIES	1/3/2024	LAC 51:XII.319.D.24 – System shall ensure that no critical water system component is in poor condition or defective.
9/19/2023	GST #3, GROUND STORAGE TANK AT PLANT	200T1 01	IESWTR APPROVED CORRECTIVE ACTION PLAN	6/29/2024	LAC 51:XII.319.D.24 – System shall ensure that no critical water system component is in poor condition or defective.

*Unregulated contaminants are those that don't yet have a drinking water standard set by USEPA. The purpose of monitoring for these contaminants is to help USEPA decide whether the contaminants should have a standard.*

Unregulated Contaminants	Collection Date	Average Concentration	Range	Unit
PERFLUOROHEPTANOIC ACID (PFHPA)	2023	3	3 – 3	ppt

\*\*\*\*\*Environmental Protection Agency Required Health Effects Language\*\*\*\*\*

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Infants and children are typically more vulnerable to lead in drinking water than the general population. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. NATCHITOCHEs WATER SYSTEM is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing a load of laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact NATCHITOCHEs WATER SYSTEM and RONNIE WILLIAMS, Business Phone: 318-352-2772.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at:

<http://www.epa.gov/safewater/lead>

Additional Required Health Effects Language:

95<sup>th</sup> Percentile Health Effects Language:

Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

There are no Additional Required Health Effects Violation Notices:

\*\*\*\*\*

DISINFECTION: The City of Natchitoches uses Chloramines as a disinfectant. We monitor 45 sites throughout the system.

Chloramines were used to control microbes.

Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The major sources of turbidity include soil runoff.

Regulated Contaminates	Collection Date	Highest Value	Range	Unit	MCL	Typical Source
Turbidity	1/2024 – 12/2024	.28	0.06 – 0.28	NTU	0.30	Soil Runoff

Regulated Contaminates	Collection Date	Lowest Percentage Value	Range	Unit	MCL	Typical Source
Turbidity	1/2024 – 12/2024	100%	100 - 100	NTU	0.3	Soil Runoff

**NOTE:** Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that cause symptoms, such as nausea, cramps, diarrhea, and associated headaches.

Regulations on Turbidity Limits:

\*from 40 CFR, Part 141.73 and 141.173 – Turbidity requirements for Surface Water Systems that filter by:









**Conventional filtration treatment or direct filtration:** the turbidity level of representative samples of a system’s filtered water must be less than or equal to a 0.3 NTU in at least 95 percent of the measurements taken. The turbidity level of representative samples of a system’s filtered water must not exceed 1 NTU.



**NATCHITOCHEs WATER SYSTEM**

Parish: **NATCHITOCHEs** PWSID: **LA1069007**

**2024 Water Grade**

 <b>Federal Water Quality</b>	<p>Points deducted for federal violations, which include Treatment Technique and Maximum Contaminant Level Violations, may pose a public health risk over an extended period of time.</p> <p style="text-align: right;">Max of 30 points</p>	<p style="text-align: center; font-size: 2em;"><b>-10</b></p>
 <b>State Water Quality</b>	<p>Points deducted for state violations, which include no water operator, inadequate water disinfection, and boil notices and water outages, may lead to other issues of concern if not resolved.</p> <p style="text-align: right;">Max of 10 points</p>	<p style="text-align: center; font-size: 2em;"><b>-2</b></p>
 <b>Financial Sustainability</b>	<p>Points deducted for lack of financial sustainability which can affect operations and maintenance of the water system. An effective water rate can provide for the repair, maintenance, and future replacement of infrastructure.</p> <p style="text-align: right;">Max of 10 points</p>	<p style="text-align: center; font-size: 2em;"><b>-0</b></p>
 <b>Operations &amp; Maintenance</b>	<p>Points deducted for operation and maintenance deficiencies noted during water system inspections, which may affect the water quality being distributed to consumers.</p> <p style="text-align: right;">Max of 15 points</p>	<p style="text-align: center; font-size: 2em;"><b>-0</b></p>
 <b>Infrastructure</b>	<p>Points deducted for infrastructure deficiencies noted during water system inspections, which may lead to unsafe drinking water and/or water service disruption.</p> <p style="text-align: right;">Max of 20 points</p>	<p style="text-align: center; font-size: 2em;"><b>-20</b></p>
 <b>Customer Satisfaction</b>	<p>Points deducted for customer complaints received by the water system and/or the Louisiana Department of Health, which are confirmed to be a water quality or quantity issue in the water system.</p> <p style="text-align: right;">Max of 10 points</p>	<p style="text-align: center; font-size: 2em;"><b>-10</b></p>
 <b>Secondary Contaminants</b>	<p>Points deducted for levels of iron and/or manganese greater than the secondary maximum contaminant levels. These levels do not pose a health risk but may cause undesirable water quality issues.</p> <p style="text-align: right;">Max of 5 points</p>	<p style="text-align: center; font-size: 2em;"><b>-5</b></p>
 <b>BONUS</b>	<p>Points granted for having an asset management plan; a storage assessment and maintenance program; well assessment &amp; maintenance program; participation in management training; or participation in a capacity development program.</p> <p style="text-align: right;">Max of 10 points</p>	<p style="text-align: center; font-size: 2em;"><b>+10</b></p>



Standard	Standard Maximum	Point Deductions	Detailed Assessment of Standards	System Deductions
Federal Water Quality	-30	5 each	Maximum contaminant level violations	0
		5 each	Treatment technique violations for Lead and Copper Rule	0
		10	Is the system non-compliant with an administrative order?	Yes
State Water Quality	-10	1 each	Chlorine violations	2
		10	Does the water system have an operator?	Yes
		5 each	Water outages and/or boil notices	0
Financial Sustainability	-10	5	Did the system submit an acceptable rate study or implement an adequate rate?	Yes
		5	Did the water system submit an acceptable audit?	Yes
		10	Is the system under a fiscal administrator for poor financial management practices?	No
		5	Are there other negative circumstances that affect fiscal control of the water system?	No
Operations & Maintenance	-15	3 each	Unresolved significant deficiencies	0
Infrastructure	-20	5 each	Unresolved significant deficiencies	4
Customer Satisfaction	-10	1 each	Valid water complaints reported	10
		10	Did the system submit a water complaint log?	Yes
Secondary Contaminants	-5	5	Manganese and/or Iron level(s) over the secondary maximum contaminant level(s)	Yes
Bonus	+10	5 each	Asset management plan, storage or well assessment & maintenance plan, participation in capacity development or management training	2
<b>Total Deductions + Bonus</b>				-37
<b>Score</b>				63 / 100 = 63%

Thank you for allowing us to continue to provide your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.

We at NATCHITOCHEs WATER SYSTEM work around the clock to provide top quality drinking water to every tap. We ask that all of our customers help us protect and conserve our water resources, which are the heart of our community, our way of life, and our children's future. Please call our office at 318-357-3850 if you have any questions.